

高雄市轄內自來水供水系統管線採樣水質檢驗結果

受檢單位 檢驗項目		序號		1	2	3	4	5	6	7
		採樣日期		114.12.1	114.12.1	114.12.1	114.12.1	114.12.1	114.12.1	114.12.2
		飲用水 水質標準		前1	前7	前5	前4	旗3	小1	左1
1	自由有效餘氯	0.2~1.0	(mg/L)	0.53	0.55	0.54	0.59	0.56	0.54	0.55
2	pH值	6.0~8.5		7.55	7.51	7.61	7.51	7.52	7.56	7.70
3	總硬度	300	(mg/L)	162	139	138	138	138	135	221
4	總溶解固體量	500	(mg/L)	346	350	334	329	337	332	433
5	亞硝酸鹽氮	0.1	(mg/L)	ND	ND	ND	ND	ND	ND	ND
6	砷	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
7	鉛	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
8	銀	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
9	鉻	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
10	總三鹵甲烷	0.08	(mg/L)	—	—	—	—	—	—	—
11	大腸桿菌群	6	(CFU/100mL)	<1	<1	<1	<1	<1	<1	<1
12	總菌落數	100	(CFU/mL)	<5	<5	<5	<5	<5	<5	<5
13	硝酸鹽氮	10	(mg/L)	—	—	—	—	—	—	—
14	硫酸鹽	250	(mg/L)	—	—	—	—	—	—	—
15	氯鹽	250	(mg/L)	—	—	—	—	—	—	—

高雄市轄內自來水供水系統管線採樣水質檢驗結果

受檢單位 檢驗項目		序號		8	9	10	11	12	13	14
		採樣日期		114.12.2	114.12.2	114.12.2	114.12.2	114.12.2	114.12.3	114.12.3
		飲用水 水質標準		左2	左3	左4	左6	左5	楠2	楠6
1	自由有效餘氯	0.2~1.0	(mg/L)	0.56	0.61	0.52	0.66	0.65	0.65	0.66
2	pH值	6.0~8.5		7.63	7.69	7.70	7.73	7.76	7.59	7.70
3	總硬度	300	(mg/L)	257	230	250	257	266	273	271
4	總溶解固體量	500	(mg/L)	332	423	378	430	350	446	465
5	亞硝酸鹽氮	0.1	(mg/L)	ND	ND	ND	ND	ND	ND	ND
6	砷	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
7	鉛	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
8	銀	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
9	鉻	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
10	總三鹵甲烷	0.08	(mg/L)	—	—	—	—	—	—	—
11	大腸桿菌群	6	(CFU/100mL)	<1	<1	<1	<1	<1	<1	<1
12	總菌落數	100	(CFU/mL)	<5	<5	<5	<5	<5	<5	<5
13	硝酸鹽氮	10	(mg/L)	—	—	—	—	—	—	—
14	硫酸鹽	250	(mg/L)	—	—	—	—	—	—	—
15	氯鹽	250	(mg/L)	—	—	—	—	—	—	—

高雄市轄內自來水供水系統管線採樣水質檢驗結果

受檢單位 檢驗項目		序號		15	16	17	18	19	20	21
		採樣日期		114.12.3	114.12.3	114.12.3	114.12.3	114.12.4	114.12.5	114.12.5
		飲用水 水質標準		楠5	楠3	楠4	楠1	鳥松1	鳳山1	大寮1
1	自由有效餘氯	0.2~1.0	(mg/L)	0.68	0.65	0.64	0.69	0.58	0.63	0.69
2	pH值	6.0~8.5		7.65	7.64	7.61	7.66	7.41	7.06	7.12
3	總硬度	300	(mg/L)	247	261	268	263	149	236	116
4	總溶解固體量	500	(mg/L)	491	484	481	-	347	424	222
5	亞硝酸鹽氮	0.1	(mg/L)	ND	ND	ND	ND	ND	ND	ND
6	砷	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
7	鉛	0.01	(mg/L)	ND	ND	ND	ND	ND	ND	ND
8	銀	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
9	鉻	0.05	(mg/L)	ND	ND	ND	ND	ND	ND	ND
10	總三鹵甲烷	0.08	(mg/L)	—	—	—	—	—	—	—
11	大腸桿菌群	6	(CFU/100mL)	<1	<1	<1	<1	<1	<1	<1
12	總菌落數	100	(CFU/mL)	<5	<5	<5	<5	<5	<5	<5
13	硝酸鹽氮	10	(mg/L)	—	—	—	—	—	—	—
14	硫酸鹽	250	(mg/L)	—	—	—	—	—	—	—
15	氯鹽	250	(mg/L)	—	—	—	—	—	—	—

高雄市轄內自來水供水系統管線採樣水質檢驗結果

受檢單位 檢驗項目		序號		22	23	24
		採樣日期		114.12.8	114.12.8	114.12.8
		飲用水 水質標準		岡山1	燕巢1	北嶺
1	自由有效餘氯	0.2~1.0	(mg/L)	0.64	0.50	0.66
2	pH值	6.0~8.5		7.74	7.49	7.64
3	總硬度	300	(mg/L)	256	250	256
4	總溶解固體量	500	(mg/L)	399	406	398
5	亞硝酸鹽氮	0.1	(mg/L)	ND	ND	ND
6	砷	0.01	(mg/L)	ND	ND	ND
7	鉛	0.01	(mg/L)	ND	ND	ND
8	銀	0.05	(mg/L)	ND	ND	ND
9	鉻	0.05	(mg/L)	ND	ND	ND
10	總三鹵甲烷	0.08	(mg/L)	—	—	—
11	大腸桿菌群	6	(CFU/100mL)	<1	<1	<1
12	總菌落數	100	(CFU/mL)	<5	<5	<5
13	硝酸鹽氮	10	(mg/L)	—	—	—
14	硫酸鹽	250	(mg/L)	—	—	—
15	氯鹽	250	(mg/L)	—	—	—